



----- LIMITS OF STANDARD BEDDING MATERIAL
 QUANTITIES FOR BEDDING MATERIAL DO NOT
 INCLUDE THE SPACE WITHIN AND BOUNDED BY
 THE OUTER SURFACE OF THE PIPE CONDUIT.

NOTE:

THIS BEDDING DETAIL SHALL BE USED FOR ALL STORM SEWER PIPE REGARDLESS OF PIPE MATERIAL. STANDARD BEDDING MATERIAL SHALL BE ODOT TYPE "A" AGGREGATE BASE OR QUICK SET FLOWABLE FILL AT THE DIRECTION OF THE ENGINEER. BEDDING AROUND PIPE ZONE SHOULD BE PER PIPE TYPE. TYPE "A" AGGREGATE BASE MUST BE TO THE TOP OF THE TRENCH UNDER PAVEMENT. TYPE "A" AGGREGATE BASE TO BE COMPACTED TO 95% STANDARD PROCTOR DENSITY.

PIPE SIZE, IN.	TRENCH WIDTH, FT.
ID < 24"	OD + 2'
24" > ID < 36"	OD + 2.5'
36" > ID < 60"	OD + 3.5'
ID = > 60"	OD + 2' EACH SIDE OF PIPE

STANDARD PIPE BEDDING DETAIL FOR STORM SEWER	
CITY OF TULSA, OKLAHOMA ENGINEERING SERVICES DEPARTMENT	
DRAWN BY: R.M.O.	APPROVED
CHECKED BY: <i>HAI</i>	<i>[Signature]</i>
DATE: MARCH 2022	
NOT TO SCALE	STANDARD NO. 751