



**NOTE:**

1. SERV. CLAMP REQUIRED FOR ALL SIZES PVC, AND FOR 6" AND SMALLER IRON. FOR 8" AND LARGER IRON, TAP DIRECTLY.
2. TAP AT ANGLE NECESSARY TO PROVIDE 30° OF COVER OVER THE SERVICE LINE.
3. COPPER SERVICE LINES SHALL BE TYPE K SOFT ANNEALED.

STANDARD METER SETTINGS FOR 1" WATER SERVICE	
CITY OF TULSA, OKLAHOMA ENGINEERING SERVICES DEPARTMENT	
DRAWN BY: R.M.O. CHECKED BY: <i>HAS</i> DATE: MARCH 2023	APPROVED 
NOT TO SCALE	STANDARD NO. 502