


NOTE: IF THE SEWER MAIN IS VCP OR RCP, THEN THE DROP SHALL BE SDR 26 PIPE AND FITTINGS WITH A MINIMUM 6' SDR 26 PIPE PUP PIECE TO THE VCP/RCP TRANSITION COUPLING

STANDARD DETAIL MANHOLE OUTSIDE DROP CONNECTIONS	
CITY OF TULSA, OKLAHOMA WATER & SEWER DEPARTMENT	
DRAWN BY: D.J.N. CHECKED BY: DATE: SEPT. 2024	APPROVED 
NOT TO SCALE	STANDARD NO. 419